CBCT-19

Core Balance CT

TECHNICAL DATA				
Insulation Level	**Frequency**	**WAPDA Spec.**	**International Spec.**	
3.6/10/40 KV to 24/50/125 KV	50/60 Hz	P-44: 2018	IEC - 61869	
Ratio	**M Class**	**P Class**	**VA**	**I_{TH} KA**
50/1A to 400/5A	0.1 M5 to 1.0 M10	5 P10 to 10 P10	1 to 2.5	Up-to 25



